



NOTE: ALL PIPING AND VALVES FOR DETAIL B SHALL BE RATED FOR 300 PSI.

VALVE & FITTING SCHEDULE				
NO.	DESCRIPTION	SIZE	SIZE	JOINT
1	DIP NIPPLE	6"	8"	FLG x PE (125#)
2	SADDLE	2"	2.5"	N/A
3	AIR VAC VALVE	2"	2.5"	FLG (ANSI 150#)
4	GATE VALVE	6"	8"	FLG (150#)
5	DIP NIPPLE	6"	8"	FLG x PE (125#)
6	FLANGE COUPLING ADAPTER	6"	8"	FLG (250#)
7	PRESSURE REDUCING VALVE (CLA-VAL 90-01)	6"	8"	FLG (ANSI 300#)
8	GATE VALVE (RESILIENT SEAT)	6"	8"	FLG (250#)
9	REDUCING TEE	6" x 2"	8" x 2.5"	FLG (250#)
10	DIP NIPPLE	6"	8"	FLG x PE (250#)
11	FLANGE ADAPTER	6" x 2"	8" x 2.5"	N/A
12	GATE VALVE (600# WOG THREADED)	2"	2.5"	N/A
13	90° ELBOW (THREADED GALVANIZED)	2"	2.5"	N/A
14	THREADED GALVANIZED NIPPLE	2"	2.5"	N/A
15	PRESSURE REDUCING VALVE (CLA-VAL 690-01) THREADED	2"	2.5"	N/A
16	THREADED GALVANIZED NIPPLE	2"	2.5"	N/A
17	90° ELBOW (THREADED GALVANIZED)	2"	2.5"	N/A
18	GATE VALVE (THREADED 600# WOG)	2"	2.5"	N/A
19	PIPE SUPPORT (STANDON MODEL S92 - 4 REQUIRED)		SIZE FOR PIPE	
20	MEGA LUG (THRUST RESTRAINT)		SIZE FOR PIPE	

- NOTES:
- RESTRAIN ALL JOINTS.
 - CLA-WALS TO HAVE SS TRIM

STANDARD #

10

DRAWN BY:
DPM

CHECKED BY:
BT

SCALE:
N.T.S.

DATE:
2/14/2018

CONSTRUCTION STANDARDS

PRV DETAIL

680 S. Woodland Hills Dr.
Woodland Hills, UT 84653
P Phone: 801-423-1962
F ax: 801-423-3501
www.woodlandhills.org

CITY OF
WOODLAND HILLS